

# 2023 ANNUAL DRINKING WATER QUALITY REPORT

Montgomery Water Authority PWSID #4410161

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda.* (This report contains important information about your drinking water. Have someone translate it for you or speak with someone who understands it.)

## **WATER SYSTEM INFORMATION:**

This report shows our water quality and what it means. Our goal is to provide you with a dependable supply of drinking water. We also want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We also want you to be informed about your water supply. Our sources are Well #1, #3 and #4 located throughout the system and are dependable ample yielding ground water sources from the Ridgley Aquifer. We are committed to ensuring the water quality of your water. If you have any questions about this report or concerning your water utility, please contact Donna Miller at 570-547-1671. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 3rd Thursday of each month at the Montgomery Borough Office at 6:30 pm.

A Source Water Assessment of our source(s) was completed by the PA Department of Environmental Protection (PADEP). The Assessment found that our source is potentially most susceptible to road deicing materials, accidental spills along roads, leaks in underground storage tanks, agricultural use, future land development and water pollution control facilities. Overall, our source has little risk of significant contamination. A summary report of the Assessment is available on the Source Water Assessment Summary Reports eLibrary web page: [www.elibrary.dep.state.pa.us/dsweb](http://www.elibrary.dep.state.pa.us/dsweb). Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the PADEP Records Management Unit at 570-327-3636.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## **MONITORING YOUR WATER:**

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2023. The State allows us to monitor some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

## **DEFINITIONS:**

*Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.*

*Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.*

*Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.*

*Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.*

*Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.*

*Minimum Residual Disinfectant Level (MinRDL) - The minimum level of residual disinfectant required at the entry point to the distribution system.*

*Level 1 Assessment – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.*

*Level 2 Assessment – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.*

*Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.*

*Mrem/year = millirems per year (a measure of radiation absorbed by the body)*

*pCi/L = picocuries per liter (a measure of radioactivity)*

*ppb = parts per billion, or micrograms per liter (µg/L)*

*ppm = parts per million, or milligrams per liter (mg/L)*

*ppq = parts per quadrillion, or picograms per liter*

*ppt = parts per trillion, or nanograms per liter*

**DETECTED SAMPLE RESULTS:****Chemical Contaminants**

Contaminant	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Barium	2	2	0.0738	0.0204 – 0.0738	ppm	3-11-21	N	Discharges from drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Nitrate	10	10	3.35	1.7 – 3.5	ppm	8-15-23	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Trihalomethanes	80	80	40.5	N/A	ppb	8-15-23	N	By-products of drinking water chlorination
Gross Alpha	15	0	8.57	N/A	pCi/L	3/20/20	N	Erosion of natural deposits
Haloacetic Acids	60	60	4.0	N/A	ppb	8-15-23	N	By-products of drinking water chlorination
Radium 226	5	0	2.09	N/A	pCi/L	3/20/20	N	Erosion of natural deposits

**Disinfectant Residual**

Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Entry Point Chlorine Residual	0.49	0.022	0.022 – 1.57	ppm	8-18-23	N	Water additive used to control microbes.
Distribution Chlorine Residual	0.20	1.19	1.19 – 1.32	ppm	Jun 2023	N	Water additive used to control microbes.

**Lead and Copper**

Contaminant	Action Level (AL)	MCLG	90 <sup>th</sup> Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	0	ppb	0	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.427	ppm	0	N	Corrosion of household plumbing.

**VIOLATIONS:**

There were no MCL or treatment violations in 2023.

On 11-20-2023 we had a low chlorine residual below the required level, but since the residual was over 0.49 ppm within 4 hours it was not a violation.

## ***EDUCATIONAL INFORMATION:***

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, can be naturally occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

## **INFORMATION ABOUT LEAD**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Montgomery Water Authority is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the *Safe Drinking Water Hotline* or at <http://www.epa.gov/safewater/lead>.